

C E R T I F I C A T E

This certifies, that the company

Alfa Valvole S.r.l.
Viale del Lavoro 19
20003 Casorezzo (MI)
Italy

Is authorized to provide the product mentioned below

Description of product: **2-ways bolted side entry trunnion mounted ball valve series T2, T4, T3, T6, 6P, 6R**

In accordance with: **EN 61508:2010 Parts 1, 2, 4, 5, 6, 7**
The product meets also the requirements of standard EN 17955:2024



Registration No 23 22451 01
Test Report No PS-29009-26-M-01
File reference 29009-01

Validity
from 2026-08-19
until 2029-08-19

Morina Guido

TÜV Nord Italia S.r.l (TÜV NORD Group)
Via Turati, 70 – 20023 Cerro Maggiore (MI) – Italy

www.tuev-nord.it

Cerro Maggiore, 2026-08-19
prodotto@tuev-nord.it

Type	A
HFT	0
Safety functions	1. Close / Open upon the demand of the actuation system 2. Close upon the demand of the actuation system, with inline tightness when in closed position
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Self-relieving - No PST	1	2,04E-08	0,00E+00	0,00E+00
Self-relieving - With PST	1	1,83E-09	1,86E-08	0,00E+00
Self-relieving - No PST	2	2,61E-08	0,00E+00	0,00E+00
Self-relieving - With PST	2	7,58E-09	1,86E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1 _H :	Applied	Route 2 _H :	Applied
	The product can be used in: - single channel configuration: - up to SIL 2 without external diagnostic tests - up to SIL 3 considering external diagnostic tests (only for Safety Function 1) - double channel configuration: up to SIL 3			
Remarks:	For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SMTR Rev. 4			

